



GEORGIA FIREFIGHTER STANDARDS AND TRAINING

FIREFIGHTER 1



Objective(s) 5.3.305, 5.3.1014,
5.3.1015, & 5.3.1016

Primary Task: INTERIOR ATTACK, DIRECT APPLICATION

Skill No. SFC-1 PERFORMANCE EVALUATION & INSTRUCTIONS SHEET

INSTRUCTIONS TO THE MONITOR/EVALUATOR

1. The candidate shall be provided with charged a fire hose with nozzle.
2. The candidate shall be provided with a structure suitable to simulate live fire control.
3. The candidate shall be informed as to where the fire is located within the structure.
4. The candidate shall be given the instructions below before beginning the exercise.

INSTRUCTIONS TO THE CANDIDATE

"The candidate shall select the proper hoseline and shall demonstrate procedures for advancing the hoseline to the fire inside the structure and attacking a fire by the direct attack method of extinguishment."

- ◆ 1. Wears full personal protective equipment.
- ◆ 2. Selects the proper size hoseline and nozzle.
- 3. Works with at least one team member.
- 4. Performs activities within the realm of an established Incident Management System.
- 5. Determines the point of entry, extinguishment should begin at the unburned side of the structure.
- ◆ 6. Bleeds the air from the hoseline.
- ◆ 7. Sets a solid or straight stream pattern on the nozzle.
- 8. Extinguishes any burning fascia, cornice, overhanging, etc.
- ◆ 9. Stays out of the doorway on the side opposite the hinges and opens door slowly.
- ◆ 10. Advances to the fire area by crawling or using duck walk.
- ◆ 11. Applies water directly to the base of the burning material.
- 12. Applies water in short burst until the fire "darkens down".

◆ **Critical Step** - Failure on this step mandates failure on the entire objective!

SAFETY IS PARAMOUNT!!

Total steps candidate must complete to Pass

9

Prevent or prohibit any unsafe acts.
Contact the Monitor at any time with any questions you may have.
Remember, you are an evaluator, not a trainer...



GEORGIA FIREFIGHTER STANDARDS AND TRAINING

FIREFIGHTER 1



Objective(s) 5.3.305, 5.3.1014,
5.3.1015, & 5.3.1016

Primary Task: INTERIOR ATTACK, INDIRECT APPLICATION

Skill No. SFC-2 PERFORMANCE EVALUATION & INSTRUCTIONS SHEET

INSTRUCTIONS TO THE MONITOR/EVALUATOR

1. The candidate shall be provided with charged a fire hose with nozzle.
2. The candidate shall be provided with a structure suitable to simulate live fire control.
3. The candidate shall be informed as to where the fire is located within the structure.
4. The candidate shall be given the instructions below before beginning the exercise.

INSTRUCTIONS TO THE CANDIDATE

"The candidate shall select the proper hoseline and shall demonstrate procedures for advancing the hoseline to the fire inside the structure and attacking a fire by the indirect attack method of extinguishment."

- ◆ 1. Wears full personal protective equipment.
- ◆ 2. Selects the proper size hoseline and nozzle.
- 3. Works with at least one team member.
- 4. Performs activities within the realm of an established Incident Management System.
- 5. Determines the point of entry, extinguishment should begin at the unburned side of the structure.
- ◆ 6. Bleeds the air from the hoseline.
- ◆ 7. Sets a solid or straight stream pattern on the nozzle.
- 8. Extinguishes any burning fascia, cornice, overhanging, etc.
- ◆ 9. Stays out of the doorway on the side opposite the hinges and opens door slowly.
- ◆ 10. Advances to the fire area by crawling or using duck walk.
- ◆ 11. Applies water to the superheated gases at the ceiling and moves the stream back and forth.
- 12. Applies water in short burst until the fire "darkens down".

◆ **Critical Step** - Failure on this step mandates failure on the entire objective!

SAFETY IS PARAMOUNT!!

Total steps candidate must complete to Pass

9

Prevent or prohibit any unsafe acts.
Contact the Monitor at any time with any questions you may have.
Remember, you are an evaluator, not a trainer...



GEORGIA FIREFIGHTER STANDARDS AND TRAINING

FIREFIGHTER 1



Objective(s) 5.3.305, 5.3.1014,
5.3.1015, & 5.3.1016

Primary Task: INTERIOR ATTACK, COMBINATION APPLICATION

Skill No. SFC-3 PERFORMANCE EVALUATION & INSTRUCTIONS SHEET

INSTRUCTIONS TO THE MONITOR/EVALUATOR

1. The candidate shall be provided with charged a fire hose with nozzle.
2. The candidate shall be provided with a structure suitable to simulate live fire control.
3. The candidate shall be informed as to where the fire is located within the structure.
4. The candidate shall be given the instructions below before beginning the exercise.

INSTRUCTIONS TO THE CANDIDATE

"The candidate shall select the proper hoseline and shall demonstrate procedures for advancing the hoseline to the fire inside the structure and attacking a fire by the combination attack method of extinguishment."

- ◆ 1. Wears full personal protective equipment.
- ◆ 2. Selects the proper size hoseline and nozzle.
- 3. Works with at least one team member.
- 4. Performs activities within the realm of an established Incident Management System.
- 5. Determines the point of entry, extinguishment should begin at the unburned side of the structure.
- ◆ 6. Bleeds the air from the hoseline.
- ◆ 7. Sets a solid or straight stream pattern on the nozzle.
- 8. Extinguishes any burning fascia, cornice, overhanging, etc.
- ◆ 9. Stays out of the doorway on the side opposite the hinges and opens door slowly.
- ◆ 10. Advances to the fire area by crawling or using duck walk.
- ◆ 11. Applies water to the to the superheated gases at the ceiling and then drops down to a direct attack of the burning material near the floor using a "T" or "Z" pattern.
- 12. Applies water until fire darkens down.

◆ **Critical Step** - Failure on this step mandates failure on the entire objective!

SAFETY IS PARAMOUNT!!

Total steps candidate must complete to Pass

9

**Prevent or prohibit any unsafe acts.
Contact the Monitor at any time with any questions you may have.
Remember, you are an evaluator, not a trainer...**



GEORGIA FIREFIGHTER STANDARDS AND TRAINING

FIREFIGHTER 1



Objective(s) 5.3.305, 5.3.1014, 5.3.1015, 5.3.1016, 5.3.1017, 5.3.1022 **Primary Task:** INTERIOR ATTACK: ABOVE GRADE LEVEL

Skill No. SFC-4 PERFORMANCE EVALUATION & INSTRUCTIONS SHEET

LEAD FIREFIGHTER

INSTRUCTIONS TO THE MONITOR/EVALUATOR

1. The candidate shall be provided with a structure with an upper floor with which to perform this objective.
2. The candidate shall be given a charged hoseline with nozzle.
3. The candidate shall be provided with a partner (to help advance the hose) with which to perform this skill.
4. The candidate shall be given the instructions below before beginning the exercise.

INSTRUCTIONS TO THE CANDIDATES

"The candidates, given a multi-story structure and a charged hoseline with nozzle, and working as a team, shall demonstrate the procedures for extinguishing an interior fire on an upper floor."

- ◆ 1. Wears full personal protective equipment.
- ◆ 2. Selects the proper size hoseline and nozzle.
- 3. Performs activities within the realm of an established Incident Management System.
- 4. Determines the point of entry, extinguishment should begin at the unburned side of the structure.
- ◆ 5. Bleeds the air from the hoseline.
- ◆ 6. Sets the proper pattern on the nozzle.
- 7. Extinguishes any burning fascia, cornice, overhanging, etc.
- ◆ 8. Stays out of the doorway on the side opposite the hinges and opens door slowly.
- ◆ 9. Advances to the stairwell by crawling or using duck walk.
- ◆ 10. Advances up the stairs by sitting or crawling keeping head up and feet down.
- 11. Keeps the hose along the outside of the stairwell.
- ◆ 12. Upon reaching the fire floor, advances to the fire room by crawling.
- 13. Applies water using an appropriate pattern.
- ◆ 14. Manages the fire stream based on the conditions.
- 15. Ensures that the fire is extinguished.

◆ **Critical Step** - Failure on this step mandates failure on the entire objective!

SAFETY IS PARAMOUNT!!

Total steps candidate must complete to Pass

11

Prevent or prohibit any unsafe acts.
Contact the Monitor at any time with any questions you may have.
Remember, you are an evaluator, not a trainer...



GEORGIA FIREFIGHTER STANDARDS AND TRAINING

FIREFIGHTER 1



Objective(s) 5.3.305, 5.2.1014, 5.3.1015, 5.3.1016, 5.3.1017, 5.3.1022 **Primary Task:** INTERIOR ATTACK: ABOVE GRADE LEVEL

Skill No. SFC-4 PERFORMANCE EVALUATION & INSTRUCTIONS SHEET

BACKUP FIREFIGHTER

INSTRUCTIONS TO THE MONITOR/EVALUATOR

1. The candidate shall be provided with a structure with an upper floor with which to perform this objective.
2. The candidate shall be given a charged hoseline with nozzle.
3. The candidate shall help advance the hose with which to perform this skill.
4. The candidate shall be given the instructions below before beginning the exercise.

INSTRUCTIONS TO THE CANDIDATES

"The candidates, given a multi-story structure and a charged hoseline with nozzle, and working as a team, shall demonstrate the procedures for extinguishing an interior fire on an upper floor."

- ◆ 1. Wears full personal protective equipment.
- 2. Performs activities within the realm of an established Incident Management System.
- ◆ 3. Stays out of the doorway on the side opposite the hinges and opens door slowly.
- ◆ 4. Advances to the stairwell by crawling or using duck walk.
- ◆ 5. Pulls slack for the lead firefighter.
- ◆ 6. Advances up the stairs by sitting or crawling keeping head up and feet down.
- 7. Keeps the hose along the outside wall of the stairwell.
- 8. Ensures the hose does not kink.
- ◆ 9. Stops at corners to pull slack around the corner, then follows the hose back to the lead firefighter.
- ◆ 10. Upon reaching the fire floor, advances to the fire room by crawling.

◆ **Critical Step** - Failure on this step mandates failure on the entire objective!

SAFETY IS PARAMOUNT!!

Total steps candidate must complete to Pass

7

Prevent or prohibit any unsafe acts.
Contact the Monitor at any time with any questions you may have.
Remember, you are an evaluator, not a trainer...



GEORGIA FIREFIGHTER STANDARDS AND TRAINING

FIREFIGHTER 1



Objective(s) 5.3.305, 5.2.1014, 5.3.1015, 5.3.1016, 5.3.1017, & 5.3.1022 **Primary Task:** INTERIOR ATTACK: BELOW GRADE LEVEL

Skill No. SFC-5 PERFORMANCE EVALUATION & INSTRUCTIONS SHEET

LEAD FIREFIGHTER

INSTRUCTIONS TO THE MONITOR/EVALUATOR

1. The candidate shall be provided with a structure with a basement or a structure that has an upper floor so that it may simulate a structure with a basement.
2. The candidate shall be given a fire hose with nozzle.
3. The candidate shall be provided with a partner (to advance hose) with which to perform this objective.
4. The candidate shall be given the instructions below before beginning the exercise.

INSTRUCTIONS TO THE CANDIDATE

"The candidate, given a structure with a basement and a fire hose with nozzle, and working as a team, shall demonstrate the procedures for extinguishing a basement fire in a structure."

- ◆ 1. Wears full personal protective equipment.
- ◆ 2. Selects the proper size hoseline and nozzle.
3. Performs activities within the realm of an established Incident Management System.
4. Determines the point of entry, extinguishment should begin at the unburned side of the structure.
- ◆ 5. Bleeds the air from the hoseline.
- ◆ 6. Sets the proper pattern on the nozzle.
7. Extinguishes any burning fascia, cornice, overhanging, etc.
- ◆ 8. Stays out of the doorway on the side opposite the hinges and opens door slowly.
- ◆ 9. Advances to the stairwell by crawling or using duck walk.
- ◆ 10. Advances quickly down the stairs by sitting and sliding down keeping head up and feet down.
11. Keeps the hose along the outside of the stairwell.
- ◆ 12. Upon reaching the basement floor, advances to the fire room by crawling.
13. Applies water using the appropriate pattern.
- ◆ 14. Manages the fire stream based on the conditions.
15. Ensures that the fire is extinguished.

◆ **Critical Step** - Failure on this step mandates failure on the entire objective!

SAFETY IS PARAMOUNT!!

Total steps candidate must complete to Pass

12

Prevent or prohibit any unsafe acts.
Contact the Monitor at any time with any questions you may have.
Remember, you are an evaluator, not a trainer...



GEORGIA FIREFIGHTER STANDARDS AND TRAINING

FIREFIGHTER 1



Objective(s) 5.3.305, 5.2.1014, 5.3.1015, 5.3.1016, 5.3.1017, & 5.3.1022 **Primary Task:** INTERIOR ATTACK: BELOW GRADE LEVEL

Skill No. SFC-5 PERFORMANCE EVALUATION & INSTRUCTIONS SHEET

BACKUP FIREFIGHTER

INSTRUCTIONS TO THE MONITOR/EVALUATOR

1. The candidates shall be provided with a structure with a basement or a structure that has an upper floor so that it may simulate a structure with a basement.
2. The candidates shall be given a fire hose with nozzle.
3. The candidate shall advance hose with which to perform this objective.
4. The candidates shall be given the instructions below before beginning the exercise.

INSTRUCTIONS TO THE CANDIDATES

"The candidate, given a structure with a basement and a fire hose with nozzle, and working as a team, shall demonstrate the procedures for extinguishing a basement fire in a structure."

- ◆ 1. Wears full personal protective equipment.
- 2. Performs activities within the realm of an established Incident Management System.
- ◆ 3. Stays out of the doorway, on the side of the door opposite the hinges.
- ◆ 4. Advances to the stairwell by crawling or using duck walk.
- ◆ 5. Pulls slack for the lead firefighter.
- ◆ 6. Advances quickly down the stairs by sitting and sliding down keeping head up and feet down.
- 7. Keeps the hose along the outside wall of the stairwell.
- 8. Ensures the hose does not kink.
- ◆ 9. Stops at corners to pull slack around the corner, then follows the hose back to the lead firefighter.
- ◆ 10. Upon reaching the fire floor, advances to the fire room by crawling.

◆ **Critical Step** - Failure on this step mandates failure on the entire objective!

SAFETY IS PARAMOUNT!!

Total steps candidate must complete to Pass

7

Prevent or prohibit any unsafe acts.
Contact the Monitor at any time with any questions you may have.
Remember, you are an evaluator, not a trainer...